ROM FOUNT (877) 794-1802	A N a i n s			_			<u>WATER</u> RGE TAN	<u>к</u>
(877) 794-1802 FINISHED GRADE (SLOPE AWAY FROM LID IN ALL DIRECTIONS) LEVEL SENSOR CONDUIT CONNECTION (OPTIONAL) FILTER RETURN CONNECTION INTERNAL S.S. SAFETY LADDER MAIN SUCTION CONNECTION				LID 	GRAVITY RETURN			
3000 PSI CONCRETE REINFORCED BALLAST PAD, BY INSTALLER	TANK E		ANCHOR TAB, TYP.	×			R 'DRY HOL ION ONLY.	.E'
		TECI	HNICAL DAT	A				
	MODEL	CAPACITY	HEIGHT 'A'	DIA. 'B'	HATCHWAY			
	RWST-500	500 GAL.	60"	60"	36x36			
	RWST-1000	1000 GAL.	72"	72"	36x36			
	RWST-1500	1500 GAL.	84"	72"	36x36			
	RWST-2000	2000 GAL.	72"	96"	36x36			
	RWST-3000	3000 GAL.	96"	96"	36x36			
<u>SPECIFICATION DATA</u> : Water Sto watertight storage. Unit complete wir requirements. <u>DESIGN/APPLICATION DATA</u> : Ron where there is no traditional pool. <u>NOTES</u> : 1. Other capacities availabl 2. Follow all 'OSHA' confine 3. Do not use for drinking w 4. Fitting sizes and location 5. Electronic level sensor c assistance & specificatio 6. Due to continuing product without notice.	th locking hatch nan Fountains e; consult fact ad space proce ater, install in s shown 'typic ontrol available ns.	hway, interna RWST-Serie ory. edures for ma path of vehic al' only. Fina e as a separa	al safety ladd es, tanks are aintenance & cles, or install I sizing and lo ate item. (Use	er, and all used for s servicing in high wa ocations w RCOM-F	I required fitting urge/storage a of tank. ater table areas vill depend on s RNF/RNFT SEF	s based on pro oplications on s. pecific job req RIES). Contact	oject design fountains systems uirements. factory for	S
© COPYRIGHT 2019 ROMAN FOUNTAINS ALL RIGHTS RESERVED	vww.romanfo	untains.com	ITEM	#	QTY		DRAWING NG 3.502	